



Fraunhofer

TESTED[®] DEVICE

OCTANORM
Partition wall types D1 and I1
Report No. OC 1004-524

DUPLICATE

Qualification Certificate

This is to certify that the products mentioned below provided by the company

OCTANORM-Vertriebs-GmbH für Bauelemente

Raiffeisenstraße 39
70794 Filderstadt
Germany

has been awarded a Fraunhofer certificate TESTED DEVICE bearing the report number OC 1004-524.

The Partition wall types D1 and I1 are suitable for use in cleanrooms fulfilling the Air Cleanliness Class 1 according to ISO 14644-1.

The operation utility is herewith recommended for use in hygienic areas possessing a cleanliness level of GMP Cleanliness Class A. However, this only applies to the operating utility when in a resting state; an overall assessment of the production environment is required after installation of the utility.

Detailed information and parameters of the test environment can be found in the Fraunhofer IPA test report.

The validity of this certificate applies only to the above mentioned product in this particular condition. For further information visit our website at www.ipa-qualification.com.

Stuttgart, September 1, 2010

[Signature]
i. A. _____
Project manager